

Strike First Corporation of America warrants its fire extinguishers to be free from defects in material and workmanship for a period of six (6) years from their date of manufacture. This warranty does not cover defects resulting from modifications, alterations, misuse, accident, abnormal conditions of operation, exposure to corrosive conditions, or improper installation or maintenance and applies to the original owner only. Goods for which a valid claim has been made will be returned to Strike First Corporation of America, and such goods will be repaired or replaced, at the option of Strike First Corporation of America. Strike First Corporation of America shall not be liable for any other loss, damage or expense, including but not limited to consequential damages, directly or indirectly arising from the condition or use of the goods or from any other cause, the exclusive remedy against the Strike First Corporation of America being to require the replacement or repair of the goods. **THIS WARRANTY IS THE SOLE AND EXCLUSIVE WARRANTY PROVIDED TO THE PURCHASER. THERE ARE NO WARRANTIES WHICH EXTEND BEYOND THE DESCRIPTION ON THE FACE HEREOF. STRIKE FIRST CORPORATION OF AMERICA HEREBY DISCLAIMS ALL OTHER WARRANTIES, EXPRESS AND IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.** This warranty is the sole and exclusive remedy of the purchaser. Strike First Corporation of America neither assumes nor authorizes any representative or other person to assume for it any obligation or liability other than as expressly set forth herein. This warranty gives the purchaser specific legal rights, and the purchaser may have other rights which vary from state to state.

## ADA COMPLIANCE

### ADA ACCESSIBLE GUIDELINE 4.4

Cabinets and Fire Extinguishers projecting from walls with their leading edges between 27 inches and 80 inches above the finished floor shall protrude no more than 4 inches into walks, halls, corridors, passageways, or aisle. Objects mounted with their leading edges at or below 27 inches above the finished floor may protrude any amount. Freestanding objects mounted on posts or pylons may overhang 12 inches maximum from 27 inches to 80 inches above the ground or finished floor. Protruding objects shall not reduce the clear width of an accessible route or maneuvering space.



**To comply with ADA Guidelines,** Extinguishers and Cabinets offer handles, brackets and return trims according to instructions provided by installer. For ADA compliance follow the specification ordering process dimensions in our catalog. Proper installation in accordance with the ADA Guidelines is the sole responsibility of the installer. For more information please visit the Accessibility Guidelines for Buildings and Facilities website or call them at 1-800-872-2253.



ADA handle option

## IMPORTANT INFORMATION

**PLEASE NOTE:** We have made every effort to make this catalog complete and accurate. We reserve the right to make changes at any time, without notice, in prices, materials, equipment, specifications, models and availability. Specifications, dimensions, measurements, and other numbers in this catalog and other printed materials provided regarding these products are approximates based upon design and engineering drawings and prototypes. Your specific cabinet may differ slightly due to variations in manufacturing and equipment. In addition, some information may have been updated since the time of printing. Please contact customer service for complete details on all products